



*The Abdus Salam  
International Centre for Theoretical Physics*



**2016-13**

**Joint ICTP/IAEA Advanced Workshop on Earthquake Engineering  
for Nuclear Facilities**

*30 November - 4 December, 2009*

**Equipment Fragility Evaluation by Vibration Test**

Hiroshi Abe  
*Japan Nuclear Energy Safety Organization JNES  
Seismic Safety Division  
Tokyo  
Japan*

ICTP/IAEA Advanced Workshop on Earthquake Engineering for Nuclear  
Facilities

# **Equipment Fragility Evaluation by Vibration Test**

**Dec. 3 2009**

**Hiroshi Abe**

Incorporated Administrative Agency  
**Japan Nuclear Energy Safety Organization (JNES)**  
**Seismic Safety Division**

---

# Content

- 1. Background**
- 2. History of vibration test**
- 3. Fragility tests outline**
- 4, Summary of 1<sup>st</sup> term**
- 5. 2nd term: Over head Crane**
- 6. Summary**

# 1. Background of the tests

## Revision of Seismic Design Guide

Old Seismic Guide:1987  
Guide:2006

Prevent to become inducible  
factors of big accidents  
against all earthquakes to be  
assumed



Revised Seismic

Cannot deny the possibility of  
occurrence of the earthquake  
which exceed assumed ones.  
“Residual risk” should be  
considered.

## Test objective change

Design Proving




Investigation of Fragility

## Background : Margin

Seismic Safety is Secured by the Design which has Certain Margin

( Seismic Margin = Functional Limit / Actual Response )



## Background : Necessity of Fragility Test



### (1) Current Fragility Data

Currently Used	Issue
Estimation from Domestic Previous Research	Thought to be smaller than the actual value, and may overestimate core damage frequency
Partial Diversion of the U.S. Data	

### (2) Objective of Tests

Grasp Realistic Fragility Data for  
Accurate Seismic Margin  
Evaluation and Seismic PSA


### Image of Core Damage Frequency Evaluation



Current  
Fragility Values

Large Fragility  
Value=Small Core  
Damage Freq.


## 2. History of Vibration Tests on Large SCCs and Introduction of Fragility Tests





## 3. Fragility Tests outline

### 3.1 Concrete Primary Containment

Reinforced Concrete Containment for ABWR




Pre-stressed Concrete Containment For PWR



Specimen ( 1/8 Scale )

( Total Weight : 595ton、Height : 5.21m、Outer Dia. : 4.0m )





Specimen ( 1/10 Scale )

( Total Weight : 757ton、Height : 6.53m、Outer Dia. : 4.6m )



# Test Condition



Acceleration Time History ( $S_2H$ )

Response Spectrum ( $S_2H$ )

## Input Motion for Reinforced Concrete Containment

- Severest Motion Selected from Design Motions of Real Plants
- Destructive Test beyond Design Condition

Test Item	Design Level Test		Margin Test
	$S_1$	$S_2$	
Structural Integrity	○	○	○
Functional Integrity	○	○	○

## Specimens on the Table




**Reinforced Concrete Containment**  
( Scale:1/8, Total Weight : 595ton  
Height:5.21m, Outer Dia: 4.0m )



**Pre-stressed Concrete Containment**  
( Scale :1/10, Total Weight: 757ton  
Height: 6.53m,Outer Dia.: 4.6m )

# Video of PCCV Destructive Test

# Summary of CCV Test



Load to Deformation Relation  
Through Excitation History  
(RCCV )

- No leak up to 5 Times S2 Excitation

- Shear Failure during 9 Times S2 Excitation and Liner Failure

- Evaluation by the amount of energy absorbed only by 9 Times S2 Excitation :

Failure at 5.8 Times S2

## Margin Evaluation by the Tests

( Equivalent One Excitation Margin Evaluated by Energy Absorbed through Excitation History )

- RCCV : 7.4 Times S<sub>2</sub>

- PCCV : 6.1 Times S<sub>2</sub>

## 3.2 Piping Ultimate Strength

**Model Simulate Structural and Vibration Characteristics of Real Piping System**

**Three Dimensional Arrangement**

**Nozzle End**


**Piping**

**Elbow and Tee**

**Restraint**

**Added Mass**

- Material : Carbon Steel (STS410)
- Dia. : 216.3mm
- Thickness : 8.2mm
- Pressure : 10.2Mpa
- Model Size : 9m x 11m x 3m(Height)
- Total Weight : 63 ton






# Test Condition

Virtual Test Condition (Input Motion, Modification of Specimen)  
that Gives 8.5 Times Stress of Allowable Limit

- Modification of Input Motion (Acceleration, Time Scale (Resonance)) and
- Modification of Specimen (Elimination of Support Points, Additional Mass)
- Stress of 8.5 Times Allowable Limit as the Result

Limitation of  
Shaking Table  
Performance






# Excitation Test

Piping Ultimate Strength Test  
(Excitation by 8.5 Times Allowable Level Input )


**Fatigue Failure during Fifth  
Excitation**



# Excitation Test


Piping Ultimate Strength Test  
(Excitation of 8.5 times of the  $IV_{AS}$  Allowable Stress Level)

## Fatigue Failure during Fifth Excitation





# Summary of the Test



Note) Design Allowable: Allowable Stress Condition VIAs ( JEAG4601)

## 3.3 Electric Panel


### (1) Specimens

Panel	Mass (t)
Main Control Board	1.0
Reactor Auxiliary Board	2.5
Logic Circuit Panel	1.0
Reactor Protection Rack	2.2
Instrumentation Rack	0.7
Reactor Control Center	0.6
Power Center	4.0
6.9kV Metal-Clad Switch Gear	5.6


### (2) Input Motion and Test Condition

Item	Condition
Basic Excitation Motion	Synthetic Motion Enveloped Actual Design Spectra (Max:1.2x9.8m/s <sup>2</sup> )
Excitation Level	Basic to 6x9.8m/s <sup>2</sup>
Electrical Condition	Active Simulating Real Operating Condition
Excitation Direction	Front to Back and Side to Side

## Panel Test: Power center and Control center



Amplification Table Spec.	
Max. Acce.	$6 \times 9.8\text{m/s}^2$
Max. Pay-Load	10 <sup>2</sup> ton



### (3) Test Result

Main Control Board, Reactor Auxiliary Board, Logic Circuit Panel, Instrumentation Rack :

**No Damage and No Malfunction up to  $6 \times 9.8 \text{ m/s}^2$  (B-F, S-S)**

Panel Name	Malfunction Mode	Input Level ( $\times 9.8 \text{ m/s}^2$ )
Reactor Control Center	Error of Magnetic Contactor Caused by Auxiliary Relay Chatter	6.1 (F-B)
Reactor Protection Rack	Error of AC Controller Card (Relay Error)	4.3 (S-S)
Power Center	Error of Breaker Closing	3.7 (F-B)
	Damage of Air Circuit Breaker	5.0 (F-B)
6.9kV Metal-Clad Switch Gear	Fall out of Fuses from GPT	2.5 (F-B)
	Damage of Vacuum Circuit Breaker	4.7 (S-S)



**Cause of Failure : Malfunction or Damage of Parts**



# Element Test (Typical)


## Test Condition

Item	Condition
Basic Input Motion	T.H. from Response Analysis of Panels
Input Level	Design Value to $10 \times 9.8\text{m/s}^2$
Electrical Condition	Same as Operation Condition
Excitation Direction	Front to Back and Side to Side

### Element Test (Differential Relay)



### Additional Element Test (Fuse of Metal-Clad Switch Gear)



Drop off of Fuse at  $2.5 \times 9.8\text{m/s}^2$  in Metal-Clad S.G. Test

After Modification of Fuse Holder :  
Function Maintained up to  $6 \times 9.8\text{m/s}^2$   
(Element Test)


# Final Evaluation of Panels

(Re-evaluation Result considering Element Tests and Modifications)


Panel Name	Critical Direction	Input Acceleration (Median)	Critical Component (Amplification Factor)
Main Control Board	S-S	5.6×9.8m/s <sup>2</sup>	Flat Display (1.7)
Nuclear Auxiliary Board	F-B	9.8×9.8m/s <sup>2</sup>	Module Switch (1.1)
Logic Circuit Control Panel	S-S	6.7×9.8m/s <sup>2</sup>	Power Source (1.7)
Reactor Protection Rack	S-S	4.4×9.8m/s <sup>2</sup>	AC Controller Card (1.9)
Instrumentation Rack	左右	4.2×9.8m/s <sup>2</sup>	Differential Pressure Transmitter (2.5)
Reactor Control Center	前後	4.5×9.8m/s <sup>2</sup>	Auxiliary Relay (1.3)
Power Center *	前後	4.4×9.8m/s <sup>2</sup>	Air Circuit Breaker (1.0)
6.9kV Metal-Clad Switch Gear *	左右	4.2×9.8m/s <sup>2</sup>	Vacuum Circuit Breaker (2.0)

Note : \*After Modification of Elements

## 3.4 Vertical Shaft Pump




( Model :RHR Pump, Scale:1/1)



# Test Condition

**Input Motion : Synthetic Wave which Envelope Design  
Spectra of BWR and PWR in Japan and Filtered  
Long Period Ingredient more than 0.9 Second  
Max. Acceleration : 3G**




Basic Horizontal Input Motion

( Envelope of Design Spectra of BWR and PWR )



# Test-scape



# Summary of the Test

## (1) Anomaly Observed in Test and Its Response Acceleration



## Structural Portions Only

Portion	Abnormal Phenomena	Response Acceleration at Relevant Portion
Motor (Anchor Bolt)	Yield	$12 \times 9.8 \text{ m/s}^2$ (Motor Top)
Pump (Barrel Support )	Yield	$30 \times 9.8 \text{ m/s}^2$ (Barrel Tip)

## (2) Max. Acceleration Where Functional Integrity was Confirmed after Anomalies were Fixed


Portion	Max. Acceleration	Max. Functional Integrity Confirmation Acceleration in Bygone Studies
Pump ( Column Tip )	$35 \times 9.8 \text{ m/s}^2$	$10 \times 9.8 \text{ m/s}^2$
Motor ( Top )	$14 \times 9.8 \text{ m/s}^2$	$2.5 \times 9.8 \text{ m/s}^2$



## 3.5 Control Rod Insertion Test of PWR and BWR

Scale : 1/1

Constitution of Specimens : Control Rod,  
Fuel Bundle, Control Rod Drive Mechanism



**PWR Specimen**

( Height : Above Shaking Table : 10.2m , Under  
Shaking Table : 6.3m )





**BWR Specimen**

( Height : Above Shaking Table : 9.3m , Under  
Shaking Table : 4.2m )


Shaking  
Table

# Outline of the Specimen


Input Motion was Made to Give Fuel Bundles and Control Rod Drive Mechanism Equivalent Response as Real Plants



# Test-Scape



PWR CR Insertion Test  
3.3S<sub>2</sub> Input Motion  
(3,139cm/s<sup>2</sup>)



BWR CR Insertion Test  
3.0S<sub>2</sub> Input Motion  
(2,141cm/s<sup>2</sup>)

# Summary of PWR CR Insertion Test


## Previous Proving Test

- Nearly Equivalent with NUPEC Test

## Functional Limit Test

- Tested up to  $3.3 \times S2$

- No Abnormality in the Test



### Simulation Analysis

□: Room Temp, & Water Flow

### This Test

●: Room Temp. & Water Flow

○: Room Temp & Still Water

### Previous Test

□: Room Temp & Still Water

Delay Time of CR Insertion vs. Relative Displacement of Fuel Bundle ( PWR )

# Summary of BWR CD Insertion Test


## Previous Proving Test

-Nearly Equivalent with NUPEC Test

## Functional Limit Test

- Tested up to 4 x S2

- No Abnormality in the Test



### Simulation Analysis

■ : High Temp.

### Simulation Analysis

□ : Room Temp.

### Functional Limit Test

● : Room Temp

### Previous Test (NUPEC)

□ : Room Temp.


Delay Time of CR Insertion vs. Relative Displacement of Fuel Bundle ( BWR )




## 3.6 Horizontal Shaft Pump

### (1) Specimen

Reactor Auxiliary Cooling Water (RCW) Pump




Specification	
Type	Double Suction Single Stage Centrifugal
Head (m)	55
Flow Rate(m <sup>3</sup> /h)	1250
Revolution (rpm)	1800
Mass (×10 <sup>3</sup> kg)	5.7






## (2) Test Method


Item	内 容
Specimen	Reactor Auxiliary Cooling Water Pump
Basic Input Motion	Synthetic Motion which Envelope Design Spectra ( $1 \times 9.8\text{m/s}^2$ )
Input Level	$2 - 6 \times 9.8\text{m/s}^2$
Pump Condition	Halt and Normal Operation Condition
Excitation Direction	Parallel and Perpendicular Direction to the Rotor Axis



### (3) Test Result



- Before Axial Shaking Test
- ▲ After Axial Shaking Test ( $6 \times 9.8 \text{ m/s}^2$ )
- ◆ Factory Test




**Input Acceleration :**  
**Max.  $6 \times 9.8 \text{ m/s}^2$**



**No Abnomality**


## (4) Bearing Element Test

### Dynamic Shaking Test of Bearings Used in Horizontal Shaft Pump



Element		Size (Type)	Quantity
Radial Bearing	Ball (Deep groove)	110mm O.D. (6310)	Three per One Element
		170mm O.D. (6316)	
	Slide (Sleeve)	60mm I.D.	
Thrust Bearing	Ball (Deep groove)	1100mm O.D. (6310)	
		170mm O.D. (6316)	
	Ball (Angular contact ) slide (Kingsbury)	170mm O.D. (7316B)	
Liner Ring	Flat	270mm, 267mm, 195mm, 175mm, 88mm (All in I.D.)	
	Groove	95.5mm I.D.	

Note: Ball bearing(6310) and 270mm liner ring are same type used in RCW pu



Test-Scape of Axial Direction


## (4) Element Test Results

### Bearing Case Vibration after Loading (Typical)

Specimen : 170mm O.D. Deep Groove Ball Bearing, Quantity 3

Loading : Dynamic Loading up to  $10 \times 9.8 \text{ m/s}^2$ , Axial

Result : Vibration Increase at Two Bearings out of Three Tested



(5) Summary of Horizontal  
Pump Test

Summary of Fragility Evaluation Considering  
Element Test

Horizontal Pump Type	Specification	Certified Acc.
Single-Stage (Test Specimen)	System : RCW Rated Flow : 1250m <sup>3</sup> /h Mass : 5700kg Bearing : 6316 ( Coupling Side ) 6316 ( Opposite Side )	8.4 × 9.8m/s <sub>2</sub>
Multi-Stage (Analogous Equipment)	System : RCW Rated Flow : 2050m <sup>3</sup> /h Mass : 8200kg Bearing : 6318 ( Coupling Side ) 7318B ( Opposite Side )	8.6 × 9.8m/s <sub>2</sub>

## 4. Summary of 1st term

Specimen	Summary of Test
Concrete Containment	<ul style="list-style-type: none"> <li>- Boundary Integrity is Secured until Destruction of Concrete</li> <li>- Margin against <math>S_2</math> : 6 Times for PCCV, 7 Times for RCCV</li> </ul>
Piping	8.5 Times of Design Allowable (Pipe Break Occurred at Fifth Excitation of 8.5 $S_2$ Test )
Electric Panels	<ul style="list-style-type: none"> <li>-No Abnormality in 6G Excitation for Main Control Board etc.</li> <li>-Malfunction Occurred in Some Panels around 2.5G Excitation, but Robustness can be Increased around 4G by Relatively Small Modification for Heavy Moving Parts or Fuse Holder</li> </ul>
Vertical Shaft Pump	Functional Integrity was Confirmed up to 12G at the Top of Motor
Control Rod Insertion	<p>PWR : Insertion Integrity was Confirmed up to 45mm Fuel Bundle Displacement</p> <p>BWR : Insertion Integrity was Confirmed up to 80mm Fuel Bundle Displacement</p>
Horizontal Shaft Pump	Functional Integrity was Confirmed up to 8.4G Excitation



## 5. 2nd term: Overhead Crane

Revised Seismic Design Review Guide requires assessment of dynamic vertical response.

At the Chuetsu-oki Earthquake a overhead crane in the Kashiwazaki-Kariwa NPP was damaged.

### ■ Test Object

- Overhead crane with garters, a trolley, a hanging load, lugs, etc.

### ■ Contents of the Test

#### • Component Tests ( in FY 2007 )

- (1) Factor analyses of the functional limit
- (2) The mutual uplift and the collision assessment of garter/trolley/hanging load
- (3) The assessment of the restitution coefficient of wheels

#### • Reduced Scale Model Test ( in Oct. 2008 )

- (1) Additional investigation point from NCE


Effect confirmation of the fall-prevention work (lug), etc.

- (2) Analysis is ongoing.

- Effectiveness of lugs was confirmed
- The uplift behavior was understood.

Video of Whole View

Video of Wheel Part



The nonlinear analysis of uplift mechanism for the vertical motions will be improved.  
The results will be applied to the integrity criteria in the seismic re-evaluation.

## 6. Summary

Application of Fragility  
Test is;

Evaluation of Residual Risk\*

\* Risk due to beyond design earthquake

Where is Functional and Structural Limit?

How far can Design Endure?

Is Designed Function Maintained?

How SSCs Response to Earthquake?



After Niigataken Chuetsu-oki earthquake, JNES refined the road map of seismic safety research for;

- 1 . Earthquake ground motion evaluation
2. Residual risk assessment
3. Seismic margin assessment
4. After earthquake action

Today I present outline of fragility test for item 2 and 3.  
If we have next opportunity, we hope to report the updated status of these researches.

We continue, through contribution for IAEA seismic safety program, to inform and to share our data and knowledge to worldwide nuclear community.

***Thank you for your attention***