



*The Abdus Salam  
International Centre for Theoretical Physics*



**2257-36**

**Joint ICTP-IAEA School of Nuclear Energy Management**

*8 - 26 August 2011*

**Innovative Nuclear Systems**

Randall Beatty  
*IAEA, Vienna  
Austria*



# **Innovative Nuclear Systems**

## ***ICTP August 2011***

*Presented by Randy Beatty, INPRO Group Leader*

*Prepared by Stefano Monti*

Nuclear Power Technology Development Section

Division of Nuclear Power



**IAEA**

International Atomic Energy Agency



# Nuclear innovation is hard

- Very conservative enterprise
- Cost of designing and certifying a new reactor concept is approximately \$1B
  - Standardization vs. innovation
- Advanced nuclear technology is not the only need
  - Communication tools
  - Regulatory tools for adapting to innovation
  - Construction techniques
  - Lessons from construction and operational experience
  - Experimental and analytical tools
- How can a Gen-IV or other advanced reactor economically compete against Gen-III or III+?



# Trends in nuclear innovation

- Technology transfer from another field
  - Exascale computing
  - Nanomaterials
  - Instrumentation and control
  - Power generation
- “Frankenstein” approach—combining the best parts to produce something powerful, some refinement needed
  - VHTR+MSR-He-UF<sub>4</sub>=AHTR
  - VHTR+SFR-Na=GFR
- Technology focused on policy goals
  - Safety
  - Nonproliferation
- Cost-effective modernization of existing plants



## To paraphrase Admiral Rickover:

An academic reactor is simple, small, cheap, light, flexible of purpose, requires little development, and can be built quickly. A practical reactor is large, heavy, complicated, expensive, is being built now, is behind schedule, and is requiring an immense amount of engineering development on seemingly trivial items.



# GIF (Generation IV International Forum) Strategy

Identify challenging goals

Create a multilateral framework for cooperation among leading nuclear development nations



Organize, grow, expand membership

## Goals

Sustainability: resources and waste management

Economics: Competitive cost and financial risk


Safety: Reliable, low risk of core damage, no EPZ

Proliferation: Not a weapons path; secure against terrorism






# From concept to demonstration



The GIF charter encompasses the complete development cycle and fuel cycle



**Horizontal Activities**  
Economics  
Safety  
Proliferation



# GIF (Generation IV International Forum)



## Goals and organization :

### ● *Sustainability*

- resources and waste management

### ● *Proliferation Resistance and Physical Protection*


- Not a weapons path; secure against terrorism

### ● *Economics*

- Competitive cost and financial risk


### ● *Safety and Reliability*

- low risk of core damage, no EP


















# The research and development organization in GIF





# Participating Nations for Generation IV System Developments



Generation IV Systems	 Argentina	 Brazil	 Canada	 France	 Japan	 Korea	 South Africa	 Switzerland	 U.K.	 U.S.A.	 EU	 China	 Russia
Sodium-cooled Fast Reactor (SFR)				○	◎	○				○	○	○	(○)
Very-high Temperature Gas-cooled Reactor (VHTR)			○	○	○	○	(○)	○		○	◎	○	
Gas-cooled Fast Reactor (GFR)				◎	○			○			○		
Supercritical-water cooled Reactor (SCWR)			○		○						◎		
Lead-cooled Fast Reactor (LFR)					○					○	○		
Molten Salt Reactor (MSR)				○						○	○		




Note ○ : Participating Nations, ◎ : Co-chair country, ( ) : Observer



# Sodium Fast Reactor outlook


- Strong national programs and experience
- Goal: Complete performance phase by 2015
- Gather fresh operating experience from existing, new and restarting reactors
- Key technical focus
  - Advanced fuels including actinide recycling
  - Converge safety approach
  - Resolve feasibility issues regarding in-service inspection and repair
  - Energy conversion systems
  - Codes and standards for high temperature application (550 C)





# Very High Temperature Reactor outlook


- Strong national programs and GIF arrangements
- Benefits from large national programs with plans for near-term prototype construction of GCRs with outlet temperatures of 750-850 C.
- Goal: Complete viability phase in 2010
- Technical focus
  - TRISO fuel (oxide and oxycarbide)
  - Hydrogen production processes
  - Core and cooling system materials
- Requirements for R&D, set power and temperature requirements (900-1000 C), move into performance and design optimization phase.





# Supercritical Water-Cooled Reactor outlook


- Merges GEN-III+ reactor technology with advanced supercritical plant technology
- Pressure vessel and pressure tube options; fast and thermal spectrum options (565 C)
- Goal: Improve knowledge base to optimize designs
- Key technology focus:
  - Materials, water chemistry, radiolysis
  - Thermal hydraulics and property changes around the critical point





# Gas-cooled Fast Reactor outlook


- Limited experience; some benefit from VHTR
- Goal: Complete viability experiments by 2012
- Key technical focus:
  - SiC clad carbide fuel
  - Safety—transient accident analysis
  - Components and materials (850 C)





# Lead Fast Reactor outlook

- No formal GIF arrangement; provisional participation
- Goal: Resolve feasibility with respect to components and corrosion control
- Key technical focus:
  - Materials
  - Design features
  - Operating parameters (800 C)






700-800 C

# Molten Salt Reactor outlook

- No formal GIF arrangement; provisional participation
- Goal: Develop design features, processing systems and operating parameters within 5 years
- Divergent paths: solid fuel with molten salt coolant; dissolved fuel in molten salt coolant
- Key technical focus
  - Resolve feasibility issues
  - Assess performance of candidate designs
  - Materials
  - In-service inspection
  - On-line salt treatment





# Outlook for horizontal activities

- Economics Methodology Working Group
  - Tool set tested on several systems
  - Available through the NEA
  - Effort is “mature”
- Risk and Safety Working Group
  - Goal is to produce an integrated framework based on PRA
  - Effort is well established; perhaps ripe for re-assessment
- Proliferation Resistance and Physical Protection WG
  - Developing methodology that has been tested on example systems
  - Would benefit from more feedback from GIF Systems





# Summary of GIF Status

- The GIF provides a unique framework for sharing the R&D burden of developing promising nuclear systems through the feasibility, viability and performance phases.
- The systems have some common challenges
  - Higher temperatures for greater efficiency and in some cases additional applications beyond electricity
  - Materials required for the higher temperature and in some cases corrosive environment
  - Advanced components including power conversion
  - Robust, reliable fuel
- Constant pressure to include old/new ideas (thorium, small reactors, etc.) in the light of new developments
- The interface with IAEA/INPRO provides an excellent opportunity to assess allocation of effort.






# Fast Reactors



## BN-600 (Russia)





# BN-600 (Russia) BASIC OPERATIONAL PARAMETERS



- On 08.04.2011, the power unit No.3 of the Beloyarsk NPP with the BN-600 reactor, being the largest operating sodium-cooled fast reactor in the world, celebrated the 31<sup>st</sup> anniversary since it was connected to the grid
- As of 21.12.2010, the BN-600 power unit:
  - had been in critical condition more than 213 000 hours;
  - had produced about 116.5 billion kW·h of electricity;
  - had operated with average value of the load factor for the period of its commercial operation since 1982 equal to 73.95%.
- On April 7, 2010, the Beloyarsk NPP received the Rostekhnadzor's license for lifetime extension of the BN-600 power unit up to March 31, 2020.
- On April 13, 2011, the BN-600 power unit was shutdown in accordance with scheduled and standard preventive maintenance works and refueling are performed now.
- In 2010:
  - 3932.61 million kW·h of electricity had been produced,
  - 256 Tcal of heat had been delivered for heat consumers from power unit's collectors.
  - NPP load factor was equal to 74.82%.



# BN-800 (Russia) under advanced construction





# BN-800 (Russia) under advanced construction



Bird's-eye view of the reactor compartment of the main building




# BN-800 (Russia) under advanced construction





# BN-1200 (Russia)



- 1 – IHX;
- 2, 3 – main and secondary pressure vessels respectively;
- 4 – supporting structure;
- 5 – inlet plenum;
- 6 – core debris tray;
- 7 – core;
- 8 – pressure pipeline;
- 9 – MCP-1;
- 10 – refueling mechanism;
- 11 – CRDM;
- 12 – rotating plugs.



# PFBR (India)

Nuclear island connected building was completed and the roof of reactor containment building was concreted partially



Lowering of Caisson in sea bed



Overall view of NICB

- TG Deck concreting
- The raft of sea water pump house
- 3 stages concreting of volute pump.




Overall view of Turbine building





33m girders & trolley of 280/85 T EOT in RCB





# Design Evolutions: PFBR to CFBR (India)





Box to plate concept




Four to eight primary pipes




Cone with torus to single torus



Large plenum to smaller plenum  
Bolted structure to welded structure



Embedded Safety vessel



Elimination of Inclined fuel transfer machine

**Material inventory reduction~ 25% , Simplified fuel handling scheme,  
Reduced manufacture time, Enhanced safety**



# Schematic of Monju (Japan)


**Electricity Output : 280MWe (714MWt), Sodium Coolant, MOX Fuel Core**

Temperature, flowrate etc.

Primary sodium reactor vessel inlet/outlet: 529/397°C, 5100 t/h/loop


Secondary sodium IHX inlet/outlet: 325/505°C, 3700 t/h/loop

Steam at the turbine inlet: 483°C, 12.5MPa, 1137 t/h






# Progress of Monju





# Japan Sodium-cooled Fast Reactor (JSFR)



Items	Specifications
Output	3,530MWt / 1,500MWe
Number of loops	2
Primary sodium temperature	550 / 395 degree C
Secondary sodium temperature	520 / 335 degree C
Main steam temperature and pressure	497 degree C 18.7 MPa
Feed water temperature	240 degree C
Thermal efficiency of plant	Approx. 42%
Fuel type	TRU-MOX
Breeding ratio	Break even (1.03) ~ 1.2
Cycle length	26 months or less, 4 batches



# CEFR (China)

Commissioning of Phase A ended

Reactor block  
installation finished



2009.8

Main building finished



2008.12

FCD



2002.8

Preparation of Site



2000.5



1998.10  
**IAEA**







# Main parameters of CEFR

<u>Parameter</u>	<u>Unit</u>	<u>Value</u>		<u>Parameter</u>	<u>Unit</u>	<u>Value</u>
<u>Thermal Power</u>	<u>MW</u>	<u>65</u>		<u>Primary Circuit</u>		
<u>Electric Power, net</u>	<u>MW</u>	<u>20</u>		<u>Number of Loops</u>		<u>2</u>
<u>Reactor Core</u>				<u>Quantity of Sodium</u>	<u>t</u>	<u>260</u>
<u>Height</u>	<u>cm</u>	<u>45.0</u>		<u>Flow Rate, total</u>	<u>t/h</u>	<u>1328.4</u>
<u>Diameter Equivalent</u>	<u>cm</u>	<u>60.0</u>		<u>Number of IHX per Loop</u>		<u>2</u>
<u>Fuel</u>		<u>(Pu, U)O<sub>2</sub> (first loading is UO<sub>2</sub>)</u>		<u>Secondary Circuit</u>		
<u>Linear Power max.</u>	<u>W/cm</u>	<u>430</u>		<u>Number of Loop</u>		<u>2</u>
<u>Neutron Flux</u>	<u>n/cm<sup>2</sup>.s</u>	<u><math>3.7 \times 10^{15}</math></u>		<u>Quantity of Sodium</u>	<u>t</u>	<u>48.2</u>
<u>Bum-up, first load max.</u>	<u>MWd/t</u>	<u>60000</u>		<u>Flow Rate</u>	<u>t/h</u>	<u>986.4</u>
<u>Inlet/outlet Temp. of the Core</u>	<u>°C</u>	<u>360/530</u>		<u>Tertiary Circuit</u>		
<u>Diameter of Main Vessel(outside)</u>	<u>m</u>	<u>8.010</u>		<u>Steam Temperature</u>	<u>°C</u>	<u>480</u>
<u>Design Life</u>	<u>A</u>	<u>30</u>		<u>Steam Pressure</u>	<u>MPa</u>	<u>14</u>
				<u>Flow Rate</u>	<u>t/h</u>	<u>96.2</u>




# Reactor block and reactor core





# CFR-1000 (China)

- 2500MWth, ~1000MWe
- MOX fuel
- BR=1.2
- Sodium as coolant
- Na-Na-H<sub>2</sub>O loops with 3 circuits of primary and secondary loop
- One turbine
- Negative feedback
- Confinement
- CDR<10<sup>-6</sup>
- Life>40y



## CFR-1000 scheme



# Main parameters of CFR-1000

Parameters	Value
Thermal power	2500 MWt
Electricity power	1000 MWe
Efficiency	40%
Loading factor	80%
Life time	>40y
Fuel	MOX
Coolant	Sodium
Primary loop type	Pool
Burn up (average)	66 MWd/kg
Burn up (maximum)	100 MWd/kg
Breeding ratio	1.2
Number of fuel subassembly (inner/out zone)	184/132
Enrichment (Inner/out)	15.3%/19%
Liner power (maximum)	29.3/49 kW/m
Total number of fuel SA	316
Rods number per SA	271

Parameters	Value
Number of control rods	30
Number of safety rod/shim rod/regulatory rod	6/19/2
Passive control rods	3
Blanket SA	255
Reflector SA	426
Spent fuel SA storage trap	381
Inner diameter of MV	14000 mm
Thickness of MV	30 mm
Sodium temperature (core inlet/outlet)	354/547°C
Sodium temperature (IHx inlet/outlet)	544/352°C
Primary loop flow rate	10100 kg/s
Loop number (Primary/secondary)	3/3
Pump number per loop	1/1
IHX number per loop	2






# Kalimer – 600 (Republic of Korea)


- |  |
|--|
| - Reactor type : pool type             |
| - Plant size : 600MWe                  |
| - Plant design lifetime : 60 years     |
| - Design basis earthquake (SSE: 0.3g)  |
| - Initial core : U-Zr metal fuel       |
| - Reloading core : U-TRU-Zr metal fuel |

- |   |
|---|
| - Plant thermal efficiency : Net > 38%  |
| - Plant availability $\geq$ 70 %  |
| - Refueling interval <ul style="list-style-type: none"><li>. U-Zr initial core : <math>\geq</math> 6 months</li><li>. TRU burner core : <math>\geq</math> 11 months</li></ul> |
| - Spent fuel storage capacity in RV <ul style="list-style-type: none"><li><math>\geq</math> 1.5 cycle discharge</li></ul>   |
| - 100 % off-site load rejection w/o a plant trip  |
| - Safety grade diesel generator   |





## ASTRID (France): Advanced Sodium Technological Reactor for Industrial Demonstration (approx. 600 MW<sub>e</sub>)





Preconceptual study by AREVA

- French government (CEA) led project: national loan 650 M€
- Industry participation - EDF operations feedback from previous reactors, utility requirements and design, safety (all aspects)
- Industry participation - AREVA : from pre conceptual to detailed design studies for the Nuclear Steam Supply System
- Other industrial partners are invited by CEA
- Current project phase: design choices to move from pre conceptual design to conceptual design coupled to ongoing R&D
- and discuss with the regulator the safety orientations (2012)



# ELSY - European Lead-cooled System






## Main parameters of ELSY (now LEADER)

	ELSY
Power, MWe	600
Thermal efficiency %	42
Primary coolant	Pure lead
Primary coolant circulation (at power)	Forced
Primary coolant circulation for DHR	Natural
Core inlet temperature °C	~ 400
Core outlet temperature °C	~ 480
Fuel	MOX with and without MA
Neutron spectrum	Fast
Fuel pin diameter, (mm)	10.5
Fuel cladding temperature (max) °C	~ 550
Active core dimensions Height/ equivalent diameter, (m)	0.9/4.32
Fuel column height. (mm)	900
N° Fuel Assemblies (FA)	162
FA geometry	Open
FA pitch, (mm)	294
N° fuel pins / FA	428
Fuel pins pitch at 20° C, (mm)	13.9 square
Enrichment, (%wt HM)	14.54/17.63/20.61 Pu, three radial zones
Power conversion system working fluid	Water-superheated steam at 18 MPa, 450° C
Primary/secondary heat transfer system	Eight Pb-to-H2O SGs





# PEACER-300 (SNU, RoK)



3D CAD Drawing of PEACER-300

Parameter	Value
Power (MWe/MWt/efficiency)	300/850/35.3
Core outlet/inlet coolant temperature (°C)	400 / 300
Primary coolant	Pb-Bi (45-55 Wt. %) eutectic alloy
Primary system cover gas pressure (atm)	1.0
Primary coolant flow rate (kg/sec)	58 000
Average power density, MWt/ m <sup>3</sup>	205
Average discharge burnup (GWd/t)	76.6
Fuel composition	U-TRU-Zr (57-32-11 Wt. %) 3 TRU Enrichment Zoning Smeared Density : 67%
Fuel assembly	PWR type open lattice (square array without wrapper)
Cladding material	HT-9
Fuel/coolant volume fraction	0.159/0.677
Fuel assembly lifetime (year)	3
Fuel pin diameter, cm	0.832
Fuel rod pitch to diameter ratio	1.44
Active core dimensions: height / diameter, m	0.50/3.82
Energy converter / balance of plant	Superheated steam cycle
Fuel cycle strategy	Full actinide recycle using pyrochemical partitioning facility
In core management	3 Batch annual reload
Passive safety	Negative temperature coefficient and Pb-Bi natural circulation
Emergency decay heat removal	Guard vessel cooling by natural circulation of air; always in effect and enhanced by LBE flooding during emergency
Design seismic acceleration (g) (horizontal, vertical)	3D Seismic Isolators (0.3, 0.2)
Electric capacity factor	90%




# Gas cooled Reactors




# SALIENT FEATURES



Dia. 60mm  
**Fuel Sphere**



**Section**



Dia. 0,92mm

**TRISO**  
**Coated Particle**



Dia. 0,5mm  
Uranium Dioxide  
**Fuel Kernel**



# OVERVIEW

## EXPERIMENTAL REACTORS



DRAGON  
(U.K.)  
1963 -1976



AVR  
(FRG)  
1967 - 1988



HTTR  
(Japan)  
1998 - Present



PEACH BOTTOM 1  
(U.S.A.)  
1967 - 1974





FORT ST. VRAIN  
(U.S.A.)  
1976 - 1989




THTR  
(FRG)  
1986 - 1989

## DEMONSTRATION OF BASIC HTGR TECHNOLOGY

PEBBLE BED MODULAR REACTOR  
PBMR

MODULAR HTGR CONCEPT  
GENERAL ATOMICS



ANTARES  
AREVA





# European Gas Fast Reactor Prototype: Allegro




- Longer term alternative technology of fast spectrum reactors for sustainability
- Able to deliver high temperature heat for industrial processes ( $H_2$  production)
- After an R&D program to consolidate preconceptual design options, ALLEGRO demonstrator (70-100 MW<sub>e</sub>) to be launched in 2012
- Central European ALLEGRO Consortium: Czech Republic, Slovakia, Hungary
- Ongoing process for Site selection and site permit (Eastern Europe)
- Euratom GoFastR collaborative project in support (22 partners)



# Material Test Reactors



**Jules Horowitz  
Reactor (*France*)  
a new European  
Testing Reactor**





**NUCLEAR AUXILIARIES  
BUILDING**

**JHR power = 100MW**  
**Start of operation 2014**

**REACTOR  
BUILDING**


Reactor  
pool

Hot cells &  
storage pools

**JHR characteristics**

51,12m x 46,75m +  $\Phi 36.6$ m

H 34,4m + H44,9 m






Up to 20 simultaneous  
experiments

Adeline  
Fuel transient  
tests

Madison  
Fuel tests in normal  
conditions


Lorelei  
LOCA tests

Calipso / Mica  
Material tests





# MYRRHA by SCK.CEN (Belgium)






# MYRRHA Core

- $k_{\text{eff}} \approx 0.95$  (ADS mode)
- 30-35 % MOX fuel
- 7 IPS positions


- 56 FAs
- 7 IPS
- 2+6 Abs
- 116 Dum
- 187 S/As



Spallation window

IPS

Fuel  
Assemblies






# BOR-60 (Russia) BASIC OPERATIONAL PARAMETERS



- *The BOR-60 reactor is used for:*
  - Material tests;
  - Isotopes production (nickel-63, strontium-89, gadolinium-153 );
  - Tests of the various equipments of fast reactors;
  - Heat and electricity production.
- *BOR-60 reactor facility is in operation more than 41 years.*
- *In December 2009, Rostekhnadzor has issued a license to RIAR for further operation of the BOR-60 reactor facility up to 31.12.2014.*




# INDICES OF BOR-60 REACTOR OPERATION IN 2010



Index	Value
Time of reactor operation on power exceeding minimum controlled level, h	5245
Reactor load factor	0.6
Max reactor power, MW	53
Energy output: heat, MW·h electricity, MW·h	251805 38480
Time of SG operation: SG-1, h SG-2, h	5173 5173
Heat delivery to consumers, Gcal	47451



# MBIR (Russia)



Lay-out of the MBIR reactor vessel and its experimental channels

- *Na-cooled Research Fast Reactor aimed at in-pile tests of new types of fuel, structural materials and various FR coolants (including Pb and Pb-Bi)*
- *Start-up of MBIR is scheduled in 2019.*



# BASIC CHARACTERISTICS OF THE MBIR REACTOR

Parameter	Value
Thermal power, MW	~150
Electric power, MW	~40
Maximum neutron flux density, $\text{n}\cdot\text{cm}^{-2}\cdot\text{s}^{-1}$	$\sim 6.0\cdot 10^{15}$
Driven fuel	Vi-pack-MOX, (PuN+UN)
Test fuel	Innovative fuels, MA fuels and targets
Core height, mm	600
Maximum core power density, kW/l	1100
Maximum neutron fluence per year, $\text{n}\cdot\text{cm}^{-2}$	$\sim 1\cdot 10^{23}$ (up to 45 dpa)
Design lifetime, year	50
Number of autonomous test loops with different coolants	up to 4
Total number of experimental subassemblies and target devices for radioisotope production	up to 12 (core) up to 5 (radial shielding)
Number of experimental channels	up to 3 (core)
Number of experimental horizontal channels	up to 6 (outside reactor vessel)
Number of experimental vertical channels	up to 8 (outside reactor vessel)



<http://www.iaea.org/inisnkm/nkm/aws/fnss/index.html>

*Thanks for Your Attention !*



*...Atoms for Peace*

