



2291-31

Joint ICTP-IAEA Course on Science and Technology of Supercritical Water Cooled Reactors

27 June - 1 July, 2011

FUKUSHIMA ACCIDENT

Katsumi Yamada

Division of Nuclear Power Department of Nuclear Energy International Atomic Energy Agency Vienna Austria

The Accident at Fukushima Nuclear Power Stations and Lessons Learned

Joint ICTP-IAEA Course on Science and Technology of SCWRs, Trieste, Italy, 27 June - 1 July 2011

Katsumi Yamada Division of Nuclear Power





- The information included here is considered most reliable at present but is subject to change according to results of the Investigation Commission set up by the Japanese Government.
- The views expressed here does not necessarily represent the official view of the IAEA.



OUTLINE

- Overview of Fukushima Daiichi and Daini Nuclear Power Stations
- The Earthquake and Tsunami
- BWR Technologies and Safety Systems
- Event Sequence at Fukushima Daiichi
 - Plant Responses and Operators Actions
- Preliminary Lessons Learned
- Current Status and Recovery Plan
- Summary



Overview of Fukushima Daiichi and Daini Nuclear Power Stations



Nuclear Power Stations (NPSs) in Japan



http://www.jaif.or.jp/ja/nuclear_world/data/image/jp_npp-location.jpg



Fukushima Daiichi and Daini NPSs

Fukushima Daiichi NPS



Fukushima Daiichi NPS



http://www.pref.fukushima.jp/nuclear/hatsudensyo/index.html

Owned and operated by the Tokyo Electric Power Company, Incorporated (TEPCO).



Fukushima Daiichi NPS





Fukushima Daiichi Nuclear Power Station

Unit #	Reactor Type	Containment Type	Electric Output (Gross)	Start of Construction	Commercial Operation	Status at Earthquake
Unit-1	BWR/3		460 MWe	1967	1971	Operation
Unit-2				1969	1974	Operation
Unit-3	BWR/4	MARK-I	784 MWe	1970	1976	Operation
Unit-4				1972	1978	Refueling Outage
Unit-5				1971	1978	Refueling Outage
Unit-6	BWR/5	MARK-II	1100 MWe	1973	1979	Refueling Outage



Fukushima Daini NPS



EA

Fukushima Daini Nuclear Power Station

Unit #	Reactor Type	Containment Type	Electric Output (Gross)	Start of Construction	Commercial Operation	Status at Earthquake	
Unit-1		MARK-II		1975	1982		
Unit-2		Improved MARK-II	1100 MWe	1979	1984	Operation	
Unit-3	BWR/5			1980	1985		
Unit-4				1980	1987		



The Earthquake and Tsunami



Plate Tectonics around Japan



Plates structure around Japan

- Pacific Plate
- North America Plate
- Philippine Sea Plate
- Eurasia Plate

- Pacific plate subducting under North America plate of 8.5 cm/yr in west
- Phillipine sea plate subducting under Eurasia plate of 6.5 cm/yr in northwest direction

Locations of principal interplate

- Along Japan trench: Plate boundary
- of pacific plate and north America one
- ·Along Nankai trough: Plate boundary of Philippine sea plate and Eurasia one



Tohoku District – Off the Pacific Ocean Earthquake

- Occurred on the boundary of the North American plate along the Japan Trench and the Pacific plate at 14:46 on 11 March 2011.
- The hypocenter was approximately 130 km off the coast of northeast Japan, and the depth was 24 km.
- Moment Magnitude Mw: 9.0



Coseismic Crustal Deformation





14

Maximum Elevation of Tsunami



15

Damages of Seawall and Harbor Installation



Destruction by tsunami scouring

Destruction by wave pressure



Casualities by the Earthquake and Tsunami

• Dead: 15,511

Missing: 7,189

 as of 30 June 2011
 (The National Police Agency)



BWR Technologies and Safety Systems





BWR: Reactor Building (R/B) and Primary Containment Vessel (PCV)



http://www.nrc.gov/reading-rm/basic-ref/teachers/03.pdf

BWR: Reactor Pressure Vessel (RPV) and its Internals

21

Nuclear Safety

- "Safety" in IAEA Safety Standards means the protection of people and the environment against radiation risk.
- It does not include nonradiation-related aspects of safety.

IAEA Safety Standards for protecting people and the environment

Fundamental Safety Principles

 Jointly sponsored by
 LUO
 IMO
 OECD/NEA
 PAHO
 UNEP
 WHO

 Image: Comparison of the sponsored by
 Image: Comparison of the sponsored by

Safety Fundamentals No. SF-1

http://www-pub.iaea.org/MTCD/publications/PDF/Pub1273_web.pdf

Concept of Defence in Depth

 "Application of the concept of defence in depth in the design of a plant provides a series of levels of defence (inherent features, equipment and procedures) aimed at preventing accidents and ensuring appropriate protection in the event that prevention fails."

Safety of Nuclear Power Plants: Design

No. NS-R-1

ATOMIC ENERGY AGENCY

http://www-pub.iaea.org/MTCD/publications/PDF/Pub1099_scr.pdf

Safety Functions

 "To ensure safety, the following fundamental safety functions shall be performed ...: (1) control of the reactivity; IAFA (2) removal of heat from the core; and Safety of Nuclear Power Plants: (3) confinement of radioactive Design materials and control of operational discharges, REQUIREMENTS as well as limitation of No. NS-R-1 INTERNATIONAL ATOMIC ENERGY AGENCY accident releases."

http://www-pub.iaea.org/MTCD/publications/PDF/Pub1099_scr.pdf

Decay Heat

- Reactor cores continue to generate heat even after the fission reactions have completely stopped.
- The heat is produced by decay of fission products, which is called 'Decay Heat'.
- The order of the decay heat is 1% of the rated power several hours after the reactor shutdown and is 0.5% at several days.
- Decay heat is a main concern in nuclear safety.

BWR Safety Systems

Control of Reactivity Control Rods (CR) Standby Liquid Control system (SLC) Removal of Heat from the Core Residual Heat Removal system (RHR) Emergency Core Cooling System (ECCS) Confinement of Radioactive Materials Primary Containment Vessel (PCV) > Other Barriers (RPV, Reactor/Building etc.)

Residual Heat Removal System

Main Functions:

- 1) Shutdown cooling mode
 - Remove decay heat after the reactor is shut down by cooling reactor water with heat exchangers.
 - Heat is discharged ultimately to the sea through sea water cooling system.
- 2) Low Pressure Core Injection mode (LPCI)
- 3) Other modes

Emergency Core Cooling System (ECCS)

• Divided into:

- High Pressure (HP) system; and
 (Automatic Depressurization System +) Low Pressure (LP) system.
- Energy for operation:
 - Turbine Driven (T/D) by steam from the RPV;
 - Motor Driven (M/D) by AC power; or
 - > Natural Force Driven (e.g. gravity).

BWR/4 Emergency Core Cooling System

BWR: Primary Containment Vessel (PCV) - MARK I Type -

- Consist of two separate volumes, a drywell and a wetwell, connecting with vent pipes.
- The drywell is a bulb-shape vessel made of steel and encloses the RPV.
- The wetwell is a torus with a large amount of water pool called 'Suppression Pool', where steam is injected and condensed to suppress the pressure increase in the PCV.

http://www.nrc.gov/reading-rm/basic-ref/teachers/03.pdf

Main Steam Isolation Valve and Safety/Relief Valve (MSIV) (SRV)

- In an emergency case when the RPV needs to be isolated, the MSIV are closed.
- If the RPV pressure increases to a preset pressure level, an SRV opens automatically and steam is injected into the suppression pool.

Event Sequence at Fukushima Daiichi - Plant Responses and Operators Actions -

Events Sequence after Earthquake [1] (Fukushima Daiichi NPS Unit 3)

EA

Inundated and Inflowed Area by Tsunami

Inundated and Inflowed Area at Fukushima Daiichi and Daini Site

All Rights Reserved @2011The Tokyo Electric Power Company, Inc.

http://www.tepco.co.jp/en/nu/fukushima-np/f1/images/f12np-gaiyou_e_1.pdf

Fukushima Daiichi and Tsunami

Cross section of Fukushima Dai-ichi (Unit-1)

Reference: The Tokyo Electric Power Co., Inc. Release [Online].http://www.tepco.co.jp/tepconews/pressroom/110311/index-j.html

Seaside Components after Tsunami (Daiichi)

Events Sequence after Earthquake [1] (Fukushima Daiichi NPS Unit 3)

Reactor Core Isolation Cooling System (RCIC)

- To inject water into the reactor when the reactor is isolated.
- Driven by steam from the RPV.
- Actuated automatically by a 'Low Water Level' signal or manually.

Events Sequence after Earthquake [1] (Fukushima Daiichi NPS Unit 3)

Events Sequence after Earthquake [2] (Fukushima Daiichi NPS Unit 3)

External Events

Internal Events and Actions

12 March 12:35

High Pressure Core Injection System (HPCI)

- To inject water into the reactor in an emergency case.
- Driven by steam from the RPV.
- Actuated automatically by a 'Low Water Level' signal or manually.

Events Sequence after Earthquake [2] (Fukushima Daiichi NPS Unit 3)

Accident Management (AM)

- Prevention and mitigation measures to a Severe Accident, an event that significantly exceeds the design basis event and could result in serious damage to the reactor core.
- Implemented by TEPCO after Chernobyl accident voluntarily (, not required by law):
 - ✓ AM Guidelines prepared;
 - ✓ PCV vent and alternate water injection systems installed; and
 - ✓ Operators trained.

Alternate Water Injection System

Events Sequence after Earthquake [2] (Fukushima Daiichi NPS Unit 3)

Events Sequence after Earthquake [3] (Fukushima Daiichi NPS Unit 3)

BWR: Primary Containment Vessel (PCV) - MARK I Type -

Two possibilities to accumulate hydrogen gas in the upper part of the R/B.

- Leakage from the PCV; or
- Reverse flow from venting line.

to stack

Events Sequence after Earthquake [3] (Fukushima Daiichi NPS Unit 3)

Unit 3 after Explosion (April 10)

http://www.tepco.co.jp/en/news/110311/images/110411_1f_5.jpg

Preliminary Lessons Learned

Preliminary Lessons Learned : Design Aspect

Safety Functions

- Reactivity control was fully satisfied.
 - All control rods were inserted into the core successfully in spite of much higher acceleration than the expectation.
- Heat removal was satisfied at first, but failed finally.
 - All external powers were lost simultaneously, but Emergency Diesel Generators (D/Gs) started automatically as designed.
 - Tsunami made all D/Gs inoperable and destroyed the sea water cooling system.
 - RCIC and HPCI worked without AC power and cooled the core for the first 1.5 days (Unit 3).

Confinement of radioactive materials was failed.

Preliminary Lessons Learned : Design Aspect (continued)

Design Basis

Protective measures against natural hazards should be reviewed and strengthened if necessary.

The height of tsunami exceeded the expectation and destroyed the seaside structures and components.

Power supply is essential. Both external and internal emergency power should be more reliable. And long-term 'All AC Power Loss' should be prepared.

Preliminary Lessons Learned : Design Aspect (continued)

Accident Management (AM)

- AM should be enhanced to prevent hydrogen explosion.
 - AM was considered and prepared before the accident, and it was helpful to some extent.
 - But it was not enough to prevent hydrogen accumulation and explosion in the R/B. (The path to the R/B has not been identified.)
- The on-site Emergency Response Centre demonstrates workers could stay under a severe circumstance.
 - Seismically robust, suitably shielded against radiation, ventilated and well equipped Centre is necessary.

Daily Meeting at Emergency Response Center (Fukushima Daiichi NPS)

http://www.tepco.co.jp/en/news/110311/images/110408_base-isolation_4.jpg

Current Status and Recovery Plan

Current Status (Fukushima Daiichi NPS)

- Units 1-3: Injecting fresh water by temporary motor-driven pumps continues in order to cool the fuels in the reactors.
- Units 1-3: Pumping out of the contaminated water with high radioactive materials in the turbine buildings in progress.
- Unit 4: No fuels in the reactor.
- Unit 5&6: Under cold shutdown.

Plant Status: Fukushima Daiichi

Plant Status: Fukushima Daiichi

- > Units 1-3: Injecting fresh water by temporary motor-driven pumps in order to cool the fuels in reactors.
- Units 2: Have launched stable circulating cooling by installing temporary heat exchangers in order to cool the fuels in spent fuel pool (SFP).
- Units 1-3: Found contaminated water with high radioactive materials in turbine buildings. Pumping out of the water into the Central Radioactive Waste Disposal Facility, etc. is in progress.
- > Unit 1: Injecting N2 into PCV to lower the possibility of hydrogen explosion. Also scheduled for Units 2&3.
- Units 5&6: Under cold shutdown.

			#1 460MW	#2 784MW	#3 784MW	#4 784MW	#5 784MW	#6 1,100MW
Pre-Earthquake Status			Operating			Shutdown for Outage		
Afi	Shutdown		O Automatic Shutdown			_		_
ter Ear	Cooling	Reactor	∆ Offsite Power Freshwater	Offsite Power Freshwater	∆ Offsite Power Freshwater	 Fuels have been removed	Cold Shutdown	O Cold Shutdown
thquak		Pool	∆ Freshwater	O Circulating cooling system	∆ Freshwater	∆ Freshwater	0	0
e	*Contai	nment	X Highly contaminated water	X Highly contaminated water	X Highly contaminated water	Δ	0	0

*There are damages on upper part of the Reactor buildings of Unit 1,3 and 4. There is a possibility of malfunction of containment in suppression chamber of Unit2. Holes were drilled on the roof of reactor buildings of Units 5 and 6 to prevent hydrogen accumulation.

*Results of the provisional analysis show that the fuel pellets of Unit 1 melted and fell to the bottom of RPV at a relatively early stage after the tsunami reached the plant. However, as the temperature of the RPV of Unit 1 is in the range of 100°C - 120°C, stable cooling is being achieved.

🔒 東京電力

All Rights Reserved ©2011The Tokyo Electric Power Company, Inc.

http://www.tepco.co.jp/en/nu/fukushima-np/f1/images/f12np-gaiyou_e_2.pdf

Recovery Plans

TEPCO Chairman's Announcement on 17 April.

- The 1st Stage (in 3 months):
 - Cool the reactors in a stable manner; and
 - Prevent water with high levels of radioactivity from flowing out of the plant.
- The 2nd Stage (in 6 to 9 months):
 - Achieve a cold shutdown of the reactors; and
 - Reduce the total amount of radioactive water.
- On-going with minor modifications.

Summary

Summary

- One of the most severe nuclear accidents has occurred at Fukushima Daiichi NPS triggered by the earthquake off the northeast coast of Japan and the subsequent tsunami waves.
- Efforts to stabilize the reactor units continue now and it is expected to take several months.
- To date no health effects have been reported as a result of radiation exposure from the accident.
- We should learn lessons to enhance safety of nuclear facilities in the world.

Main Information Sources

- "Report of Japanese Government to the IAEA Ministerial Conference on Nuclear Safety – The Accident at TEPCO's Fukushima Nuclear Power Stations –", Government of Japan, June 2011 (http://www.kantei.go.jp/foreign/kan/topics/201106/iaea_houkokusho_e.html)
- "Analysis of Operating Records and Accident Records Fukushima Daiichi NPS at Time of the Tohoku-Pacific Ocean Earthquake and an Evaluation of its Effects", Tokyo Electric Power Company, 23 May 2011. (In Japanese) (http://www.nisa.meti.go.jp/earthquake/files/houkoku230523-1.pdf)
- 3. Status of Fukushima Daiichi and Fukushima Daini Nuclear Power Stations after Great East Japan Earthquake, TEPCO Homepage (http://www.tepco.co.jp/en/nu/fukushima-np/index-e.html)

... Thank you for your attention.

