



## **Altheim in Upper Austria – an example of cascaded geothermal energy use**


***International School on Geothermal Development***

*Trieste – 11-Dec-2015*

# Geothermal Project in the Upper Austrian Molasse




- Usage of low-enthalpy geothermal water in the Austrian part of the Molasse Basin has been established since historic times
- More recently, the geothermal water flows have been studied more carefully with respect to origin, flow directions and coordinated offtake



# Altheim Geothermal Project – Geology




- The Phase I of the Altheim geothermal project: supply of hot water to the community for district heating of approx 1,500 households, requiring energy of some 10 MW<sub>[th]</sub>
- A vertical production well was drilled to a TD of ~2,300 m (Upper Jurassic), well flowed water with 46 l/sec at 104° C in free (artesian) flow
- In 1994, electrical submersible pump (ESP) was installed to increase flow to 100 l/sec; a directional disposal well was drilled; a 1 MW, ORC turbine was added for power generation



# Altheim Geothermal Project – Flow Diagram




- The 104° C hot water flow from the production well is diverted into two streams
- After passing through a plate type heat exchanger and depending on ambient temperature, ~ 8 to 9 MW<sub>[th]</sub> at 90° C secondary closed loop flow are used for residential heating of public buildings and private residential premises
- The remainder of the hot water flow is directed to an Organic Rankine Cycle (ORC) turbine and power generator with a capacity of approx 1 MW<sub>[el]</sub>
- The ~70° C outflow from the ORC power plant is cascaded to the local school and indoor swimming pool heating system with a capacity of approx 1 MW<sub>[th]</sub>




# Ecological Impact and Energy Production



- Ecological Footprint was materially reduced by reducing emissions from fossil fuels use



- Total production of almost 400 GWh over last 13 years (majority of the low enthalpy geothermal water being used for district heating)



# Economics of Geothermal Project



Base Assumptions		Fill in value
Parameter		Calculated
Depth of the well	2,800	[m]
Geothermal gradient	0.038	[K/m]
Reservoir temperature	106.4	[°C]
Flow of the well	100.0	[l/s]
Well head temperature	102.5	[°C]
Reinjection temperature	58.4	[°C]
Conversion efficiency thermal power	96.0	[%]
Full load hours per year	8,000	[h]
Thermal Power	17.7	[MW]
Thermal Energy	141.6	[GWh]
Heating hours per year	3,200	[h]
Heating energy per year	56.6	[GWh]
Annual growth heat sales	1.0	[%p.a.]
District heating wholesale price per MWh	30.0	[EUR]
Electricity per year	10.2	[GWh]
Received price per MWh electricity sold	50.0	[EUR]
Size of electric power station	1.8	[MW]
Total Investment	17.0	[MMEUR]
Conversion efficiency electric power	12.0	[%]
Price increase for electricity bought	4.0	[%p.a.]
Price increase general costs	3.0	[%p.a.]
Price of CO <sub>2</sub> Emission	5.0	[EUR]
Capacity of 1 W =	1.16222	[kcal/h]

CAPEX			Depreciation
Parameter			
Well Drilling	6.0	[MMEUR]	30 [yrs]
Drilling Contingency	0.0	[MMEUR]	30 [yrs]
Building and Land	0.5	[MMEUR]	15 [yrs]
Submersible Pump	1.0	[MMEUR]	5 [yrs]
Heating Losses	2.0	[MMEUR]	5 [yrs]
District Heating Pipeline	5.0	[MMEUR]	30 [yrs]
Plant and Facilities	2.5	[MMEUR]	20 [yrs]
Other/Miscellaneous	0.0	[MMEUR]	5 [yrs]
<b>Total CAPEX € million</b>	<b>17.0</b>	<b>[MMEUR]</b>	

OPEX	
Parameter	
Increase in provisions	48.0 [MEUR p.a.]
Material and third party costs	0.0 [MEUR p.a.]
thereof electric power	0.0 [MEUR p.a.]
thereof oil	0.0 [MEUR p.a.]
Personnel costs	100.0 [MEUR p.a.]
Other operating expenses	200.0 [MEUR p.a.]
Other operating	0.0 [MEUR p.a.]
Start up costs	0.0 [MEUR p.a.]
Maintenance	2.0 [MEUR p.a.]
<b>Total OPEX</b>	<b>350.0 [MEUR p.a.]</b>

Results		
	BT	AT
Internal rate of return (ROR)	10.3%	9.2% [%]
Net present value (NPV)	6.8	4.8 [MMEUR]
Pay back period	12.6	14.4 [years]

.... back to main presentation

petro  
prom